

Procurement of 09 Nos of UPSs					
No	Page No	Clause No	Current Description	Suggestion by bidder	BEC Clarification / Recommendations
1	19	ITB 11.1 (e) 4	The bidder shall be in the business as of the nature of the goods and services of this contract for at least Last five (05) years. Documentary evidence shall be Submitted. (If not attached, the bid offer shall be Treated as a non-responsive bid.	<p>Bidder must have at least 10 Years' experience in UPS Industry.</p> <p>As per the proposal, Bidders have to give 05 Years warranty. We would like to emphasize that well recognized organizations which has more than 10 years' experience in the UPS industry able to comply this requirement. Systems has to be deployed Islandwide and availability of islanded branch network with the trained technical team is mandatory for this requirement. As per the market experience most of the small scale companies' with less number of years of experience shutdown the operation without a prior notice and customers not able get a after sales support within the warranty period and after the warranty.</p>	Remain Unchanged
2	34,40,46	Specifications 17. Bidders Qualifications	10 Year Experience for quoted brand in Sri Lanka (Proof needed be attached)	<p>10 Years' experience for quoted brand as well as the Bidder.</p> <p>Bidders must have well experience on the quoted product and identified the failures and rectify the issue immediately.</p>	Refer amendment 01
3	19,22	ITB 11.1 (e) 6, Section III	Bidder must have ISO 50001quality certificates to this effect Shall be	ISO 50001quality certificate is applicable for UPS or Battery.	Refer amendment 01

		(b) (iii)	enclosed with the Bid.	This Certificate will be given to the equipment Manufacturers.	
4		Specification sheet (But Not Mentioned)	Coating Treatment for Sea breeze	Coating Treatment on all PCBs in UPS Systems which will be installed in Harbors and locations which expose to the sea. PCBs will be corroded due to the sea breeze. Purchaser has to bear the cost after the warranty period	Remain Unchanged
5	30	Section v 2 i,ii,iii	Delivery Period Within 10 weeks from awarding the Contract.	Keep Unchanged Some of the systems are tailor made as per comply with the Specification it will take extra time in addition to that it will take time to sail from the Manufactures location (Italy) to Sri Lanka.	Remain Unchanged
6	32	Section V , 8 Battery , Backup time for 20 KVA UPS	Battery arrangement in the UPS, In built Batteries only	Keep Unchanged. Limited Space allocated (Confirmed by the Panel assigned by the Purchaser) and it is not keep the 20 KVA UPS system on the external Battery Bank due to Height, Weight and safety of the users.	Remain Unchanged
7	44	Battery Cut off Voltage	1.75 V/Cell	1.75 V/ Cell @ 25 °C This must be applicable for all the batteries which comes with the all the UPS Systems.	Refer amendment 01
8	34,40,46	Scope of Work	Feeder Cables, Mentioned a common length for all UPS Systems	Length for each & every locations. Length for each location to reduce the cost for feeder Cables.	Please refer Scope of Work
9	64	Section VII,	Payment Schedule. Initial 70 % Balance	Settle the full payment after the	Refer amendment 01

		Contract Data CC 15.1	30% after 5 Years	<p>delivery and the commissioning of the systems.</p> <p>Settle the full payment after the delivery and the commissioning of the systems because Clause number CC 17.1 has requested the performance security equal to 10% of the total contract sum.</p>	
10	65	CC 17.1	The Bidder also requested to submit an extra guarantee in the value of 3%. (of the contract value) valid for 28 days beyond the completion of warranty period from date of delivers completion of commissioning of the UPS.	<p>Agreed to remove the Clause during the pre bid meeting.</p> <p>This will be make extra price increase for the proposal due to opportunity cost.</p>	Refer amendment 01
11	34,40,46 & 22	17. Bidders Qualifications & Section III Experience and Technical Capability	<p>10 Year Experience for quoted brand in Sri Lanka (Proof needed be attached)</p> <p>The bidder must be a company registered in Sri Lanka for a period of more than five (05) years .The bidder shall provide copies of original documents defining the constitution or legal status, place of registration, and principal place of business. The bidder shall be in the business as of the nature of the goods and services and of this contract for at least last five years.</p>	<p>In the Technical Specifications, it is stated that the bidder must have 10 years of experience with the quoted brand. However, in the Evaluation Criteria, the requirement is 5 years of the bidder's overall experience.</p> <p>Please confirm which of these requirements will be applied during evaluation.</p>	Refer amendment 01
12	33,39,45	Section V Technical Specification- Battery Design Lifetime	10 years or higher (manufacturer confirmation should be attached)	<p>Please note that for 12V 26Ah batteries or below capacity, the standard/default design life is 8 years for all such batteries.</p> <p>Kindly confirm whether batteries of this capacity and design life will be</p>	Remain Unchanged

				acceptable for consideration.	
13	34,40,46	Section V Technical Specification- Scope of Work	The wiring for the input and output connectivity should be three phase compatible	DIE committee said some locations wiring has been done , therefore please kindly provide the wiring require location	Please refer Scope of Work
14	32	Section V Technical Specification- Battery	Minimum 30 minutes @ per 60% load	we will have to cater this requirement with external battery bank , therefore we kindly request from DIE to change “ Battery arrangement in the UPS “ as in build or external battery	Remain Unchanged
15	30	Section V Delivery Schedule	Delivery period as 10 Weeks from the date of awarding the contract	change the delivery period up 16 to 18 weeks	Remain Unchanged